

WAIVER REQUESTS

1. (3.3 (13)) We request a waiver for wetland delineation criteria and wetland scientist stamp. The wetland boundary used was previously delineated by Gove Environmental Services as part of the September 2020 boundary survey by Atlantic Survey. No impact to existing wetland is proposed.
2. (4.7) We request a waiver from drainage design. Less than 10% (7.7%) of the parcel is becoming impervious area. The proposed infiltration trench between the propose structure and on-site wetland area will attenuate any increase in runoff by allowing the runoff to infiltrate into the excessively drained Hinckley Soil and will also prevent any siltation from moving to the wetland.
3. We request a waiver from professional certifications. We believe that the previous survey should cover the licensed land surveyor requirement. The simplicity and low density development of the site should allow the septic designer license to cover the minor grading of the site.

Connor McDougal